

Pergamon

PII: S0273-1223(99)00497-7

SIMULTANEOUS NITRIFICATION AND DENITRIFICATION USING SIPORAXTM PACKING

P. Menoud, C. H. Wong, H. A. Robinson, A. Farquhar, J. P. Barford and G. W. Barton

Department of Chemical Engineering, University of Sydney, NSW 2006, Australia

ABSTRACT

In this paper, we examine a biofilm process for simultaneous removal of ammonia and NO_x (nitrite and nitrate). Siporax T^M a porous Raschig-ring type filter specifically designed and manufactured for fast colonisation by micro-organisms, was used to demonstrate the feasibility of simultaneous nitrification (usually an aerobic process) and denitrification (usually an aerobic or anoxic process) inside a single reactor. Clear evidence was found that denitrification occurred inside the internal pore structure of Siporax T^Mrather than in an anoxic zone near the outlet of the reactor. The reactor was operated continuously and maximum nitrification and denitrification capacities of 0.61 and 0.83 g N/(Lday), respectively were observed in this study. © 1999 Published by Elsevier Science Ltd on behalf of the IAWQ. All rights reserved

KEYWORDS

Immobilised medium; simultaneous nitrification and denitrification; SiporaxTM, synthetic wastewater.

INTRODUCTION

Modern biological wastewater treatment processes need to be able to perform nitrification as well as denitrification. In conventional sewage treatment plants, the two reactions are carried out in different tanks or at different times (eg. in a sequencing batch reactor). This is because nitrification occurs in an aerobic environment while denitrification prevails in the absence of oxygen. However, the two reactions are complementary in many ways, i.e. nitrification produces nitrite/nitrate which are the reactants in denitrification, while denitrification generates alkalinity that is required in nitrification. There are thus obvious advantages to having both reactions happening at the same time.

In biofilm and bio-floc processes, the basic concept of simultaneous nitrification and denitrification is to create an oxygen concentration gradient across the micro-organism based agglomerates, so that both aerobic and anaerobic conditions can be established inside a single reactor. Under these conditions, both the nitrifiers and denitrifiers can prevail in performing their associated biological transformations. Kokufuta *et al.* (1988) and Santos *et al.* (1993) proposed immobilization of pure cultures of nitrifiers and denitrifiers in gels, but this is expensive and it suffers from the great fragility of such gels. Schott (Germany) have produced sintered glass Raschig rings, under the trademark of SiporaxTM. This porous glass matrix is robust and has a very high internal surface area, as well as being specifically designed for fast colonization by micro-organisms.

P. MENOUD et al.

Given the specified desirable features of SiporaxTM, the goal of this project is to develop a Siporax TMbased biofilm process to achieve simultaneous nitrification and denitrification. The basic concept of simultaneous nitrification and denitrification with SiporaxTM is to create an oxygen concentration gradient across the ring, so that both aerobic and anoxic conditions can be established within the SiporaxTM ring. Aerobic nitrifiers growing outside the SiporaxTM consume oxygen and provide a shield (preventing against mass transfer of oxygen) for the anoxic denitrifiers to grow inside the internal pore structure.

Early work on Siporax TM (Dawes, 1989; Göbel and Untergasser, 1995) focused on aquarium applications, which usually have a relatively low nutrient concentration. The work presented in this paper, however, was aimed at demonstrating the application of Siporax TM for treatment of municipal wastewater. Experimental studies were carried out with synthetic wastewater of pre-defined ammonium and nitrate concentrations. The wastewater was fed into a Siporax TM packed column and the concentrations of ammonium, nitrite and nitrate at the outlet of the column were regularly monitored. The column was subjected to step loadings of nitrate and ammonium to test the robustness of the system. The results of these studies are summarised in this paper.

METHODS

Experimental set-up

Two sets of experimental work were carried out. In the first set of experiments, the feed solution was not cooled. The feed was fed in an upward direction to the 700 mm long column while air was introduced in the feed tank. However, this set-up was found to promote biological activity in the feed tank. As a result, regular changes of the feed solution were required. To avoid the need for frequent changing of the feed solution, the experimental set-up was modified in the second experimental campaign such that there was an air gap between the feed and the SiporaxTM. The modified set-up is shown in Figure 1.



Figure 1. Set-up for the experiments with Siporax[™].

As shown in Figure 1, a feed solution, kept at 10°C in a glass flask, was pumped using a peristaltic pump to the top of a 53 mm inside diameter column. The laboratory was temperature controlled at 25°C. The column was packed with SiporaxTM Raschig rings to give a total packing height of 200 mm. See Table 1 for the specification of SiporaxTM. Before the SiporaxTM rings were packed inside the column, they were preinoculated by soaking overnight in nitrifying-denitrifying activated sludge obtained from a local sewage treatment plant. The level of liquid in the column (270 mm in this case) was adjusted by the level of the

154

outlet tubing and the effluent was collected in a container. Air from the laboratory supply was introduced to the liquid at the top of the column through a gas sparger. This was done to minimize any biological activity in the feed tank. The ammonium concentration in the feed tank was also monitored from time to time to ensure that there was no biological contamination in the feed tank.

Manufacturer:	Schott Glaswerke, Mainz, Germany
Material:	Sintered glass
Dimensions:	15 mm diameter, 15 mm length
Open pore volume:	up to 70%
Pores sizes:	60-300 μm
Inner surface area:	$1 \text{ m}^2/\text{g}^2$
Distributed weight:	286 g/l
Material density:	Approximately 0.7 g/cm ³

Table 1. Specifications of Siporax[™] Raschig rings

Medium

A synthetic wastewater with a pre-defined composition was used in this study. Two different media were used for the two different sets of experiments, their compositions are shown in Table 2.

Chemical Campaign 1		Campaign 2		
Glucose	1001 mg (1067 COD mg)	282 mg (300.8 COD mg)		
NH4C1		$107 \text{ mg} (28 \text{ mg} \text{ NH}_4^+ - \text{N})$		
NH4NO3	80 mg (14 mg NH_4^+ -N and 14 mg NO3 ⁻ N)	$80 \text{ mg} (14 \text{ mg NH}_4^+-\text{N and } 14 \text{ mg NO}_3^\text{N})$		
KH2PO4	$30 \text{ mg} (6.8 \text{ mg} \text{ PO}_4^{3} \text{-P})$	$44 \text{ mg} (10 \text{ mg} \text{PO}_4^{3} - \text{P})$		
K ₂ HPO ₄	$15 \text{ mg} (2.7 \text{ mg} \text{ PO}_4^3 \text{-P})$	-		
NaHCO3	•	504 mg (366 mg HCO ₃ ⁻)		
Nutrient solution	1 ml	1 ml		

Table 2. Per	litre com	positions o	of the two	media
--------------	-----------	-------------	------------	-------

Glucose, which is known to be readily biodegradable, was used as the carbon source. Nitrate was added to promote initial denitrification, otherwise the denitrifiers would be without an electron acceptor until full nitrification was achieved. Sodium bicarbonate was added to promote nitrification as well as providing a pH buffer.

The nutrient solution contains per litre: 90g MgSO₄7H₂O, 6g CaCl₂2H₂O, 1.5g FeCl₃6H₂O, 6.5g MnCl₂4H₂O, 1.7g ZnSO₄7H₂O, 0.1g CuCl₂2H₂O, 1.9g CoCl₂6H₂O, 6.5g NiSO₄6H₂O, 0.1g H₃BO₃, 0.6g (NH₄)₆Mo₇O₂₄4H₂O, 1g yeast extract.

Sampling and analytical methods

Intermittent sampling was performed by withdrawing a 5 ml aliquot from the feed and effluent solutions. The effluent aliquot was filtered with a 0.22 μ m MilliporeTM filter unit to remove particulates and give a sterile sample. The samples were analysed immediately on a Merck Spectroquant[©] spectrophotometer for the ammonium, nitrate and (occasionally) nitrite concentrations. The Spectroquant[©] methods used were 14752, 14773 and 14776 for ammonium, nitrate and nitrite, respectively. Ammonium analysis utilises Berthelot's reaction to form a blue indophenol dye that absorbs at 690 nm. Nitrate analysis utilises a reaction involving nitrate in acidic conditions where a deep red nitro-compound that absorbs at 515 nm is formed. The nitrite determination follows Griess' reaction in which nitrite is transformed into a violet-red azo dye that can be measured at 525 nm. Standard deviations for the three methods are 2%, 7% and 1%, respectively.

Monitoring of dissolved oxygen, pH and flow rate

The dissolved oxygen concentration (DO) was measured at both the top and the outlet of the column. A Ox20 meter and a O21B probe (Bacto Laboratories) were used to perform the DO measurement. Samples from the feed and effluent solutions were taken and the pH values of the samples were determined with a pH330 meter and a Sentix 21 electrode (Merck). Effluent flow rate was determined with a stop watch and a measuring cylinder.

RESULTS AND DISCUSSION

Experimental campaigns

Two experimental campaigns were carried out. Table 3 summarises the different periods of the experimental studies, while Figure 2 and Figure 3 show the results for both experiments.

			D	escript	ion			Du	ration	_
Cam	oaign 1									
Run I	.0	Stabilisation (2.9 l/d)				Day 0-17				
Run 1	.1	Nitrate step increase from 14 to 70 mg NO ₃ -N/1			-N/l	Day 17-32				
Run 1	.2	Flow rate st	tep increa	se from	2.9 to	9.0 I/d		Day 32	2-35	
Camp	oaign 2									
Run 2	.0	Stabilisatio	n (1.7 l/d)				Day 0-	28	
Run 2	.1 1	Flow rate st	tep chang	e						
	t	from 1.7 to	3.4 l/d					Day 28	3-37	
	i	from 3.4 to	6.6 Vd					Day 37	7	
	1	from 6.6 to	3.4 I/d					Day 37	7-42	
_Run 2	.2	After clogg	ing					Day 43	3-56	_
75	↓	Run 1.0		▶ 4		Run 1.1		- > -	10 n 1.2	
Nutrient concentration, mg/		· · · · · ·	· · · ·		• • • •		+		+ 3 + 3 + 3 + 3 + 3 + 3 + 3 + 3 + 3 + 3 - 2 - 1 - 10	рн, -
0	4	8	12	16	20	24	28	32	36	

Table 3. Description of the two experimental campaigns

Time, day

Figure 2. Experimental campaign 1: Height of the SiporaxTM packed bed is 700 mm. Average pH and DO concentration in the feed are 6.8 and 8.0 mg/l, respectively. Average DO concentration in the effluent is 3.6 mg/l. inlet NH₄⁺-N, _____ inlet NO₃⁻-N, _____ outlet NH₄⁺-N, _____ outlet NO₂⁻-N, _____ outlet NO₃⁻-N, _____ outlet PH.



Stabilisation

In both sets of experiments, it can be seen that the micro-organisms in the column took approximately 1-2 weeks to acclimatise to the new environment, as shown in Figure 2 and Figure 3. This is a relatively short time compared to the acclimatisation period usually observed for other biofilm processes such as a trickling filter. In the first set of experiments, the initial nitrate-nitrogen concentration in the effluent was found to exceed the influent concentration. This shows the contribution of nitrate-nitrogen from nitrification (NH4 \rightarrow NO3), in addition it also suggests that the success of denitrification is controlled or delayed by the establishment of nitrifier colonies outside the SiporaxTMring, so that an anaerobic environment is available inside the Siporax TMring. In the second set of experiments, no such delay was observed. This is attributed to the fast colonization of the nitrifiers, which is enhanced by the addition of bicarbonate in the feed since autotrophic nitrifiers use inorganic carbon as their cell carbon source.

Once adapted to the new conditions, both nitrifiers and denitrifiers were found to be capable of removing both ammonia and nitrate to low concentrations in the range of $0-5 \text{ mg N } 1^{-1}$.

Location of the denitrifiers

The primary goal of this project was to demonstrate the feasibility of simultaneous nitrification and denitrification with SiporaxTM. Specifically, the aim was to demonstrate that denitrification was occurring inside the pore structure of SiporaxTM instead of along the length of the column, i.e. an aerobic zone followed by an anoxic zone. To show this, the dissolved oxygen concentration was measured at both the inlet and the outlet of the column. In general, a DO concentration higher than about 0.5 mg/l is known to inhibit denitrification (Rittmann and Langeland, 1985). Although the inhibition mechanism is not clear, it is well accepted that at a high DO concentration, denitrifiers can switch their electron acceptor from nitrate to oxygen, thereby ceasing to denitrify.

In our experimental systems, simultaneous nitrification and denitrification was consistently observed for an effluent DO concentration in excess of 2.0 mg/l. Average effluent DO concentrations for experimental

P. MENOUD et al.

campaigns 1 and 2 were 3.5 mg/l and 2.0 mg/l, respectively. This demonstrates that denitrification was occurring inside the pores of the SiporaxTM rings rather than in an anoxic zone near the outlet of the column.

Step increase in nitrate concentration

A five-fold step increase in the inlet nitrate-nitrogen concentration was used to disturb the column performance, see Figure 2. However, both nitrifiers and denitrifiers were found to adapt to the new conditions in less than two weeks, providing effluent essentially free of both ammonia and nitrate.

Although nitrite was not introduced in the influent, nitrite at low concentrations was detected throughout the experiment. This confirms nitrite as the intermediate for a two-step nitrification scheme, and the low concentration of nitrite suggests that the first step is the rate-limiting step.

$$NH_4^+ + \frac{3}{2}O_2 \rightarrow HNO_2 + H^+ + H_2O \qquad (Step 1)$$

$$HNO_2 + \frac{1}{2}O_2 + H_2O \rightarrow HNO_3 + H_2O \qquad (Step 2)$$

Step changes in feed flow rate

Numerous changes in the feed flow rate were carried out (see Table 3). The process was found to be very robust when subjected to changes in feed flow rate, as seen in Figure 2 and Figure 3. No noticeable changes in the effluent ammonium and nitrate concentrations were observed when the flowrate was increased. The micro-organisms were found to adapt to the new flow rate almost instantaneously.



Figure 4. Enlargement of the experimental results shown in Figure 3. The experimental conditions are as listed under Figure 3.

Figure 4 shows an enlargement of the flow rate increase from 1.7 to 3.4 l/d in experimental campaign 2. Within 3 hours, most of the shock was "absorbed" and the effluent ammonium and nitrate concentrations returned to their previous levels (ie. before the flow rate increase) in about 3 to 7 days. Note the relatively low level of the nutrient concentration (0-2 mg/l).

158

Clogging and unclogging of the column

In both columns, clogging occurred after a period of 40-45 days. In the second set of experiments, the column was washed out. Two litres of water, introduced from the outlet of the reactor, were found necessary to unclog the 0.4 litre reactor. After washing, the column was found to return to its previous performance level within six days.

Loading capacity for simultaneous nitrification and denitrification

In Table 4, we compare nitrification and denitrification capacities found in this study with those in the literature. Most systems found in the literature focus on either nitrification or denitrification, therefore, only a limited comparison can be drawn. As shown in Table 4, the nitrification and denitrification capacities of the current system are in the same order of magnitude as those found in the literature, and it is obvious that there is still room for improvement in the SiporaxTMsystem.

Table 4. Comparison of nitrification and denitrification capacities of the Siporax[™]s ystem with those reported in the literature

	Nitrification, kgN / (m ² .day)	Denitrification, kgN / (m ³ .day)
Run 1.1-1.2	0.03-0.08	0.16-0.49
Run 2.1	0.16-0.61	0.21-0.83
Garrido et al. (1997)	5.00	-
Koch and Siegrist (1997)	-	1.00
Lazarova et al. (1997)	1.00-1.50	-
Pochana and Keller (1997)	0.19-0.46	0.19-0.34
Semon et al. (1997)	-	1.90

CONCLUSIONS

Overall, this study demonstrates the feasibility of simultaneous nitrification and denitrification with Siporax TM. It was clearly demonstrated that denitrification occurred inside the pores of the Siporax rings, as the outlet DO concentration was consistently higher than 1 mg/l, a concentration level known to inhibit denitrification. The system is fairly robust, as it shows a quick response when subjected to major perturbations such as changes in feed flow rate. A maximum simultaneous nitrification/denitrification capacity of 0.61/0.83 gN/(litre.day) is estimated in this study. Further work is being undertaken to optimise the nitrification and denitrification capacities of the system.

ACKNOWLEDGEMENTS

We would like to acknowledge:

- Schott, Germany for the supply of the Siporax[™] rings used in this study.
- Liverpool Sewage Treatment Plant, Sydney Water, for supplying the nitrifying-denitrifying sludge used to inoculate the Siporax[™] rings.
- Australian Research Council for their financial support.

REFERENCES

Dawes, J. (December, 1989). A Schott in the arm for biological filtration. Aquarist & Pondkeeper, 6-7.

Garrido, J. M., Campos, J. L., Mendez, R. and Lema, J. M. (1997). Nitrous oxide production by nitrifying biofilms in a biofilm airlift suspension reactor. *Wat. Sci. Tech.*, 36(1), 157-163.

Göbel, M. and Untergasser, D. (1995). SiporaxTM, the high performance filter material for the biological purification of aquaria. Schott Product Information, No. 80047 e.

Koch, G. and Siegrist, H. (1997). Denitrification with methanol in tertiary filtration at wastewater treatment plant Zurich-Werdholzli. Wat. Sci. Tech., 36(1), 165-172.

P. MENOUD et al.

- Kokufuta, E., Shimohashi, M. and Nakamura, I. (1988). Simultaneously occurring nitrification and denitrification under oxygen gradient by polyelectrolyte complex-coimmobilized Nitrosomonas europaea and Paracoccus dentrificans cells. Biotechnol. Bioeng., 31, 382-384.
- Lazarova, V., Nogueira, R., Manem, J. and Melo, L. (1997). Control of nitrification efficiency in a new biofilm reactor. Wat. Sci. Tech., 36(1), 31-41.
- Pochana, K. and Keller, J. (1997). Study of factors affecting simultaneous nitrification and denitrification (SND). Biological Nutrient Removal 3, Brisbane, Australia, 30th November – 4th December, 1997. Conference proceeding, 470-477.
- Rittmann, B. E. and Langeland, W. E. (1985). Simultaneous denitrification with nitrification in single-channel oxidation ditches. J. Water Pollut. Control Fed., 57(4), 300-308.
- Santos, V. A., Tramper, J. and Wijffels, R. H. (1993). Simultaneous nitrification and denitrification using immobilized microorganisms. Biomat. Art. Cells Immob. Biotech., 21(3), 317-322.
- Semon, J., Sadick, T., Palumbo, D., Santoro, M. and Keenan, P. (1997). Biological upflow fluidized bed denitrification reactor demonstration project – Stamford, CT, USA. Wat. Sci. Tech., 36(1), 136-146.